



**NOTES:**

**SOFT METAL PIPE FLASHING:**

- SHEET LEAD: MINIMUM OF 2-1/2 LB. PER SQUARE FOOT OR
- SHEET COPPER: MINIMUM 16 OZ.

IF USING COPPER FLASHING OVER AN IRON OR STEEL PIPE, INSERT A SEPARATOR SHEET (E.G., ASPHALT SATURATED ROOFING FELT), WRAPPED AROUND PIPE, TO SEPARATE THE COPPER FLASHING FROM DIRECT CONTACT WITH PIPE, TO REDUCE GALVANIC ACTION.  
VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING.

<b>TITLE</b>	
Pipe Penetration Flashing	
<b>Name</b>	
Detail No. CTR-604	
<b>Drawn By:</b>	<b>Reviewed BY:</b>
JA	KF
Applicable to all Flex CTR Roof Systems	
<b>FLEX MEMBRANE INTERNATIONAL</b>	2670 Leiscz's Bridge Rd. Leesport, PA 19533 800-969-0108 www.flexmembranes.com