



**NOTE:**

1) METAL EXTENDER PIECE IS REQUIRED IF EXISTING COUNTERFLASHING IS CONTAMINATED AND OR COUNTERFLASHING FASCIA IS LESS THAN 4 INCHES WIDE. FASTENED 12 INCHES O.C. WITH GROMMETTED FASTENER.

2) VAPOR BARRIER SHALL BE SEALED AT EDGES.

TITLE  
CURB FLASHING-REMOVABLE UNIT

NAME  
DETAIL NO. 3.40

DRAWN BY:  
KF

DATE:  
07/2007

APPLICABLE TO FLEX

ADHERED SYSTEMS

FLEX  
MEMBRANE  
INTERNATIONAL

2670 LEISCZ'S BRIDGE RD.  
LEESPORT, PA 19533  
800-969-0108  
www.flexmembranes.com