



NOTE:

1) METAL EXTENDER PIECE IS REQUIRED IF EXISTING COUNTERFLASHING IS CONTAMINATED AND OR COUNTERFLASHING FASCIA IS LESS THAN 4 INCHES WIDE. FASTENED 12 INCHES O.C. WITH GROMMETTED FASTENER.

2) VAPOR BARRIER SHALL BE SEALED AT EDGES.

| | |
|-----------------------------------|---|
| TITLE | |
| CURB FLASHING REMOVABLE | |
| NAME | |
| DETAIL NO. 3.40 | |
| DRAWN BY: | DATE: |
| KF | 07/2007 |
| APPLICABLE TO ALL FLEX | |
| MECHANICALLY FASTENED SYSTEMS | |
| FLEX MEMBRANE INTERNATIONAL | 2670 LEISCZ'S BRDIGE RD. LEESPORT, PA 19533 800-969-0108 www.flexmembranes.com |