



NOTE:

1) METAL EXTENDER PIECE IS REQUIRED IF EXISTING COUNTERFLASHING IS CONTAMINATED AND OR COUNTERFLASHING FASCIA IS LESS THAN 4 INCHES WIDE. FASTENED 12 INCHES O.C. WITH GROMMETTED FASTENER.

2) VAPOR BARRIER SHALL BE SEALED AT EDGES.

TITLE	CURB FLASHING NON-REMOVABLE	
NAME	DETAIL NO. 3.50	
DRAWN BY:	KF	DATE: 07/2007
APPLICABLE TO ALL FLEX MECHANICALLY FASTENED SYSTEMS		
FLEX MEMBRANE INTERNATIONAL	2670 LEISCZ'S BRIDGE RD. LEESPORT, PA 19533 800-969-0108 www.flexmembranes.com	