



**NOTES:**

- 1) MINIMUM THICKNESS OF INSULATION SHALL BE 1.5"-1.9"
- 2) SEE FACTORY MUTUAL APPROVAL GUIDE FOR APPROVED FASTENERS/PLATES
- 3) FM 1-90 FASTENING PATTERN
- 4) REFER TO LOSS PREVENTION DATA SHEET 1-29 OR CONSULT THE ROOF SYSTEM MANUFACTURER FOR PERIMETER AND CORNER ENHANCEMENT RECOMMENDATIONS.

|                                   |   |
|-----------------------------------|---|
| TITLE FLEX ISO II, FLEX ISO III   |   |
| NAME DETAIL NO. FLEX ADHERED 3    |   |
| DRAWN BY: KF                      | DATE: 07/2007   |
| APPLICABLE TO FLEX                |   |
| ADHERED SYSTEMS                   |   |
| FLEX<br>MEMBRANE<br>INTERNATIONAL | 2670 LEISCZ'S BRIDGE RD.<br>LEESPORT, PA 19533<br>800-969-0108<br>www.flexmembranes.com |