



NOTES:

- 1) MINIMUM THICKNESS OF INSULATION SHALL BE 2"
- 2) SEE FACTORY MUTUAL APPROVAL GUIDE FOR APPROVED FASTENERS/PLATES
- 3) FM 1-90 FASTENING PATTERN
- 4) REFER TO LOSS PREVENTION DATA SHEET 1-29 OR CONSULT THE ROOF SYSTEM MANUFACTURER FOR PERIMETER AND CORNER ENHANCEMENT RECOMMENDATIONS.

TITLE FLEX INSULATION ATTACHMENT METHOD I	
NAME DETAIL NO. 1.01	
DRAWN BY: KF	DATE: 07/2007
APPLICABLE TO FLEX	
ADHERED SYSTEMS	
FLEX MEMBRANE INTERNATIONAL	2670 LEISCZ'S BRIDGE RD. LEESPORT, PA 19533 800-969-0108 www.flexmembranes.com