



- NOTES:
- LOCATE FLEX TERMINATION MUST BE A MINIMUM OF 8" IN VERTICAL HIGHT FROM FIELD MEMBRANE.
 - 1. 6" X 6" FLEX TPO PLUS FLASHING OVERLAY REQUIRED AT FIELD SPLICE INTERSECTIONS WHEN .060" THICK FLEX TPO REINFORCED MEMBRANE IS USED AS WALL FLASHING.

TPO 3.07
 PARAPET CURB FLASHING